



## OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 419 - Public Drinking Water Equipment Performance - Filtration

This is the Official Listing recorded on March 7, 2017.

**Amiad Water Systems Ltd.**  
**D.N. Galil Elyon 1**  
**12335**  
**Israel**  
**800-243-4583**  
**704-662-3133**

**Facility: Israel**

Microfiber Filter <sup>[1]</sup>

AMF2 -36K DW <sup>[2]</sup>      AMF2 -93K DW <sup>[3]</sup>      AMF2-370K DW <sup>[4]</sup>

[1] Certified by NSF for Cryptosporidium removal efficiency, with a mean log removal value (LRV) of 2.76 log, and a minimum LRV of 2.15 log.

[2] Tested at maximum design flow rate of 44 gpm.

[3] Certified flow rate of 114.4 gpm.

[4] Certified flow rate of 457.5 gpm.